



AGA CERTIFIED PRODUCT

Certificate Holder: **RUBINETTERIE UTENSILERIE BONOMI SRL**

ABN/ACN No. (if applicable): **N/A**

Manufacturer: **RUBINETTERIE UTENSILERIE BONOMI SRL**

Agent (if applicable): **N/A**

Type of Component: **MANUAL BALL VALVE (TYPE 1)**
Temperature rating: 0 – 60°C

Model No. & Description: **RUB**
(Refer www.aga.asn.au for more details)
S84 & S84GW – [F/F & M/F]
NB 1/4", 5/8", 1/2", 3/4", 1", 1 1/2", 2"
(8, 10, 15, 20, 25, 32, 40, 50mm)
MWP 2100kPa
S24 – [F/F]
NB 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"
(15, 20, 25, 32, 40, 50mm)
MWP 2100kPa
S84 - [F/F & M/F]
NB 2 1/2", 3" & 4"
(65, 80, 100mm)
MWP 1500kPa

Note: Various thread forms available in accordance to AS ISO 7.1

Relevant Standard(s): **AS 4617 – 2004 (Including Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




Reviewing Officer


Certificate Authorised

Certificate first issued: **16 March 1995**

Certificate No: **5244**

This copy valid from: **14 November 2011**

Refer specification issue: **07**